

Option 1
Up size approximately 6,900 lf of
existing 8" water main to 12" to
achieve a fire flow of approximate
2,500 gpm at the project site

Construct new 0.5 MG water tank.
Install at approximate elevation 1080'
(elevation near Mt. Pleasant and
Turkey Hill Rd.) and install
approximately 1,900 lf 12"
watermain.

